

ADDENDUM NO. 1

Date: December 15, 2021

**INVITATION FOR BIDS CANYON COUNTY
FAIR PEDESTRIAN BRIDGES PROJECT**

See Attached Exhibit "1," incorporated by reference herein, which consists of Addendum No. 1 to Canyon County's Invitation for Bids Canyon County Fair Pedestrian Bridges Project.

Approved this 15 day of December, 2021.

BOARD OF COUNTY COMMISSIONERS

Commissioner Leslie Van Beek



Commissioner Keri K. Smith



Commissioner Pam White

ATTEST: CHRIS YAMAMOTO, Clerk



Deputy Clerk

Date: 12-15-21

**ADDENDUM NO. 1
OVERVIEW**

Date: December 15, 2021

Invitation for Bids for Canyon County Fair Pedestrian Bridges Project

To: All Bidders

BID DUE DATE: As stated in the Calendar of Events, bids must be delivered to the Clerk, Board of County Commissioners' Office, Canyon County Courthouse, 1115 Albany Street, Caldwell, Idaho 83605, no later than **8:59 a.m., Monday, December 20, 2021.**

1. NOTICE TO BIDDERS:

- A. This Addendum shall be considered part of the original Canyon County, Idaho's Invitation for Bids ("IFB") for Canyon County Fair Pedestrian Bridges issued by the Board of County Commissioners on November 29, 2021.
- B. Bidders are hereby notified that they shall make necessary adjustments in their bids based upon this Addendum.
- C. This Addendum consists of:
 - Cover Sheet (1 page)
 - Addendum No. 1 Overview (1 page)
 - Miscellaneous Clarifications/Questions (2 pages)

**ADDENDUM NO. 1
QUESTIONS AND CLARIFICATIONS**

Date: December 15, 2021

Invitation for Bids Canyon County Fair Pedestrian Bridges Project

TO: All Bidders

Proposals Due: 8:59 a.m. Monday, December 20, 2021

Miscellaneous Clarifications:

1. The following information as well as the IFB will be available on the County website at www.canyonco.org.
2. The County received inquiries into the specifications of the project. The specifications were included in the IFB on the County website. They are also included below for ease of access:

Specifics:

Prefabricated bridges with specifications below. The bridge needs to be fabricated from atmospheric corrosion resistant weathering steel. Floor shall be galvanized composite floor deck (with concrete and rebar by others).

Style: Crossbow
Bridge 1: Width 10', Span 50'
Bridge 2: Width 12', Span 50'
Finish: Weathering
Floor: 5" NW Concrete
Number of pieces: 1
Design Criteria: AASHTO
Live Load (psf): 90
Dead Load (psf): 76-74
Vehicle Load (kips) 10 – 20
Lifting Weight (lbs): NTE 13,500
Vert. Reaction (kips): 41.5-49.2
Horiz. Reaction (kips): 3.6 – 3.6
Truss Height (feet): NTE 6'
Railing Height: 54"
Safety Rails: Horizontal
Rail Opening: 4"

ADDENDUM NO. 1
INVITATION FOR BIDS
CANYON COUNTY FAIR PEDESTRIAN BRIDGES

EXHIBIT "1"

Handrail: Wood

Abutment to be designed and built by others, Electrical to be supplied and installed by others, bridges to be placed by onsite contractor. Excludes: sales tax, permitting, site conditions, crane services, deck concrete, unloading, site erection, embedded anchor bolts.

Proposal needs to include shop drawings stamped by a professional Engineer registered in the state of Idaho.

Questions:

1. No written questions were submitted.