

ADDENDUM NO. 1

Date: May 11, 2023

TO: CANYON COUNTY'S INVITATION FOR BIDS CANYON COUNTY FAIR EVENT CENTER FENCE PROJECT

See Attached Exhibit "1," incorporated by reference herein, which consists of Addendum No. 1 to Canyon County's Fair Event Center Fence Project.

Approved this 11th day of May, 2023.

BOARD OF COUNTY COMMISSIONERS



Commissioner Leslie Van Beek

Commissioner Brad Holton

Commissioner Zach Brooks

ATTEST: CHRIS YAMAMOTO, Clerk



Deputy Clerk

Date: 05.11.23

**ADDENDUM NO. 1
OVERVIEW**

Date: May 11, 2023

Canyon County Fair Event Center Fence Project

To: All Bidders

BIDS DUE DATE: As stated in the Calendar of Events, Bids must be delivered to the Clerk, Board of County Commissioners' Office, Canyon County Courthouse, 1115 Albany Street, Caldwell, Idaho 83605, no later than **8:59a.m. on May 16, 2023.**

1. NOTICE TO BIDS:

- A. This Addendum shall be considered part of the original Canyon County, Idaho's Invitation for Bids ("IFB") for Canyon County Fair Event Center Fence Project issued by the Board of County Commissioners on **April 13, 2023.**
- B. Bidders are hereby notified that they shall make necessary adjustments in their Bids based upon this Addendum.
- C. This Addendum consists of:
 - Cover Sheet (1 page)
 - Addendum No. 1 Overview (1 page)
 - Miscellaneous Clarifications (1 page)

**ADDENDUM NO. 1
QUESTIONS AND CLARIFICATIONS**

Date: May 11, 2023

Canyon County Fair Event Center Fence Project

TO: All Bidders

Bids Due: May 16, 2023

Miscellaneous Clarifications:

1. The following information as well as the IFB will be available on the County website at www.canyoncounty.id.gov.


Questions:

1. Written questions were submitted by: Idaho Fence Masters – Scott Brock
 - Q.1. 6' tall iron fencing comes in many variations. Commonly known as "western 3 rail, or western 2 rail, and others. Could we get a clarification on the "style of iron fencing desired?
 - A.1. 3 rail vista-style ornamental wrought iron panels
 - Q.2. Is the fence to be installed on open ground meaning grass, gravel etc. or will it be placed on asphalt or concrete which requires core drilling?
 - A.2. Open ground for majority of fence. Core drilling will be necessary for gates on concrete and asphalt.
 - Q.3. Gates- More details are needed to construct the desired gates. Drawings, or photos to ensure conformity.
 - A.3. See Attachment No. 1 for promotional material that illustrates a potential design of the slide gates and swing gates. This example is not binding. The selected contractor will be responsible for design and installation of the gates.

Attachments included in Addendum No. 1:

1. Example of design for slide gates and swing gates.





Attachment 1