

ADDENDUM NO. 1

Date: May 31, 2024

**TO: CANYON COUNTY'S SOLICITATION OF BIDS
FLEET SHOP HVAC PROJECT**

See Attached Exhibit "1," incorporated by reference herein, which consists of Addendum No. 1 to Canyon County's Fleet Shop HVAC Project.

Approved this 31st day of May, 2024.

BOARD OF COUNTY COMMISSIONERS



Commissioner Leslie Van Beek



Commissioner Brad Holton



Commissioner Zach Brooks

ATTEST: RICK HOGABOAM, Clerk



Deputy Clerk

**ADDENDUM NO. 1
OVERVIEW**

Date: May 31, 2024

FLEET SHOP HVAC PROJECT

To: All Bidders

BID DUE DATE: As stated in the miscellaneous clarifications section, bids must be delivered to the Clerk, Board of County Commissioners' Office, Canyon County Courthouse, 1115 Albany Street, Caldwell, Idaho 83605, no later than Tuesday, June 11, 2024 at 9:00 a.m.

1. NOTICE TO BIDDERS:

- A. This Addendum shall be considered part of the original Canyon County, Idaho's Solicitation of Bids for the Fleet Shop HVAC project issued by the Board of County Commissioners on May 21, 2024.
- B. Bidders are hereby notified that they shall make necessary adjustments in their Bids based upon this Addendum.
- C. This Addendum consists of:
 - Cover Sheet (1 page)
 - Addendum No. 1 Overview (1 page)
 - Questions and Clarifications (2 pages)

**ADDENDUM NO. 1
QUESTIONS AND CLARIFICATIONS**

Date: May 31, 2024

FLEET SHOP HVAC PROJECT

TO: All Bidders

Bids Due: June 11, 2024 at 9:00 a.m.

Miscellaneous Clarifications:

1. The following information, as well as the Solicitation of Bids will be available on the County website at www.canyoncounty.id.gov.
2. **PLEASE NOTE THE FOLLOWING IMPORTANT CHANGES** to dates listed in the Solicitation of Bids issued May 21, 2024:
 - Objections to the specifications or bid procedures must be received in writing or email by **Tuesday, June 4, 2024 at 5:00 p.m.**
 - Bids must be identified with the subject line “Canyon County Fleet Shop HVAC Project,” and be received by **Tuesday, June 11, 2024 at 9:00 a.m.** Bids will be opened on **Tuesday, June 11, 2024, at 9:30 a.m.**

Bids and objections must be directed to the Canyon County Board of Commissioners via direct delivery or email at bocc@canyoncounty.id.gov

Questions:

Questions from Pre-Bidder’s Conference on May 29, 2024:

- Q.1. Confirm either way if DDC controls will be included in our proposal or if they will be retrofitted after the project is complete.
- A.1. The DDC controls will be installed after the project is completed. They should not be included in proposals.
- Q.2. Will there be any special requirements for flashing the duct penetrations through the PEMB? Oftentimes the company who builds these buildings have a warranty and like to be there to flash in any penetrations to make sure the warranty is protected.
- A.2. No special requirements as the warranty has expired due to the age of the building. The County requires a professional appearance and components fully sealed to the outside elements.

- Q.3. Confirm if modifications to the duct will be allowed. For instance, converting the round duct outside of the building into square, internally lined duct with 3" insulation as required by code.
- A.3. Modifications must comply with all code, and be approved by the County.
- Q.4. Confirm that the electrical work and conduit will be installed by others.
- A.4. All electrical work for the new HVAC unit will be done by the County.